


FRONT VIEW



SIDE VIEW

EXPLOSION PROOF PUSH BUTTON STATION

TECHNICAL SPECIFICATION

Type of Ex-Protection	EEx-d Type, IS/IEC60079-1:2007
Zone Classification	Zone 1 & Zone 2
Gas Group	IIA, IIB, IIC T6 IS/IEC60079-0:2004
Ingress IP Protection	Ip66 IS/IEC60529-1:2001
Material of contraction	High Pressures Die Cast Aluminum Alloy Lm6
Paint	Epoxy Polyester Powder Coating
Earthing	Internal -01 No. External -02 Nos.
Cable Entry	02 Nos. for M20 (3/4 ET)
Hardware	Stainless Steel
Green Push Button	START with 1NO Contact element for 10 AMP
Red Push Button	STOP Mushroom Head Pad Lock with NC Contact 1

TRI-FLP ENGINEERS PVT. LTD.

11, 1st Floor, Popular Indl. Estate, Gokhale Compound,
 Raghuvir Nagar, Near Char Rasta, Dombivli East,
 Dist Thane 421201, Maharashtra, India.

Tel : +91 0251 2433393 / 2452001 / 2440071 / 2440081

Email : vikas@trimurtitriflp.com / triflp@gmail.com

Web : www.explosionproof.co.in

